



CITY OF MORENO VALLEY
FIRE PREVENTION DIVISION
14177 Frederick Street
Moreno Valley, CA 92552 • Ph 951.413.3370

PRE-APPROVED ADU FIRE FLOW LETTER

Date: _____ **Address:** _____

Case Number: _____ **APN:** _____

This is certification the water system shall state the system is capable of meeting the following required fire flows as determined by the California Fire Code Appendix B.

Based on the information provided on the above referenced case.

The fire flow required for this project will be (select one):

☐ 1000 G.P.M. for duration of 1-HOUR measured at 20-psi residual pressure for ADU's not equipped fire sprinkler system.

OR

☐ 500 G.P.M. for a duration of ½-HOUR measured at 20-P.S.I. residual pressure equipped with a fire sprinkler system.

The required fire flow may be adjusted during the approval process to reflect changes in design, construction type or automatic fire protection measures as approved by the Fire Prevention Bureau.

**Applicant/
Developer:** _____

By: _____ **Date:** _____

Title: _____

WATER AGENCY APPROVAL

Name of Agency: _____

Address: _____

Telephone: _____ **Date:** _____

By: _____ **Title:** _____

NOTE: THE COMPLETION AND SUBMITTAL OF THIS LETTER TO THE FIRE PREVENTION BUREAU SHALL NOT BE CONSTRUED AS APPROVAL FOR THE INSTALLATION OF THE REQUIRED FIRE HYDRANT(S) AND/OR WATER SYSTEM.